



NSF Product and Service Listings

These listings are current as of **Monday, October 10, 2011** at 12:15 a.m. Eastern Time. Please [contact NSF](#) for the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://www.nsf.org/Certified/PwsComponents/Listings.asp?Company=C0078023&Standard=061&>

NSF/ANSI STANDARD 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings.](#)

EonCoat LLC

4000 Airport Drive Northwest
Wilson, NC 27896
United States
252-360-3110

[Visit this company's website](#)

Facility : Wilson, NC

Protective (Barrier) Materials

Trade Designation	Water Contact Size Restriction	Water Contact Temp	Water Contact Material
Coatings - Fittings EonCoat[1]	>= 100"	CLD 23	CERAM
<p>[1] Colors: White Number of Coats: 1 Maximum Field Use Dry Film Thickness (in mils): 36 (maximum 6 per pass) Recoat Cure Time and Temperature: Allow 5 second pause between each pass Final Cure Time and Temperature: 24 hours at 35° F - 110° F Special Comments:Mix ratio of Part A:Part B is 1:1 by volume.</p>			
Coatings - Pipe EonCoat[1]	>= 100"	CLD 23	CERAM
<p>[1] Colors: White Number of Coats: 1 Maximum Field Use Dry Film Thickness (in mils): 36 (maximum 6 per pass) Recoat Cure Time and Temperature: Allow 5 second pause between each pass Final Cure Time and Temperature: 24 hours at 35° F - 110° F Special Comments:Mix ratio of Part A:Part B is 1:1 by volume.</p>			
Coatings - Pipe - Immediate Return to Service [2] EonCoat[1]	>= 100"	CLD 23	CERAM

